



Pimpri Chinchwad Municipal Corporation
Pimpri, Pune – 411018.
Phone :- 020- 67331110/1120
Fax :- 020- 27425600
E-Mail :- commissioner@pcmcindia.gov.in
Web :- www.pcmcindia.gov.in

NO – ws/lab/1937/2025

Date – 25/11/2025

To

The Principal,
Novel International School,
Sambhajinagar, Chinchwad.

Subject: Water sample Potability Certificate.

Drinking water sample provided by Novel International School, Sambhajinagar, Chinchwad. on Date: 19/09/2025 was analysed for Chemical and Bacteriological analysis. As per the analysis reports no. ws /lab /1752/2025 dated 21/09/2025 & ws /lab /1748/2025 dated 20/09/2025 the water Samples are safe for drinking purpose.

The Bacteriological & chemical analysis reports are attached herewith.

Note-The water sample not drawn by this laboratory


CHIEF CHEMIST
Water Treatment Plant
Pimpri Chinchwad Municipal Corp
Nigdi, Pune 44

PIMPRI CHINCHWAD MUNICIPAL CORPORATION



(W/S) DIVISION

REPORT OF BACTERIOLOGICAL EXAMINATION OF WATER

No-WS/LAB/1748/2025.

Date - 20 / 09 /2025

DATE OF EXAMINATION - 19 / 09 /2025.

NAME - Novel International School

ADDRESS - Sambhajinagar, Chinchwad.

SOURCE -

SR.NO.	WATER SAMPLE (PLACE)	RESIDUAL CHLORINE (PPM)	CONCLUSION MPN/100ml		REMARK
			Coliforms	E.Coli	
1	R.O Water	Nil	0/100ml	-	Potable
2	PCMC Water.	Nil	0/100ml	-	Potable.
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					

CHIEF CHEMIST
Water Treatment Plant
Pimpri Chinchwad Municipal Corp.
Nigdi, Pune 44

PIMPRI CHINCHWAD MUNICIPAL CORPORATION
(W/S) DIVISION



REPORT OF CHEMICAL EXAMINATION OF WATER

NAME - Novel International School.

No-WS/LAB/1752/2025.

ADDRESS - Sambhajinagar, Chinchwad.

Date - 21 / 09 /2025.

SOURCE - R.O Water.

Date of Receipt - 19 / 09 /2025.

Date of Examination - 21 / 09 /2025

Sr.No.	Tests	I. S Standards for Drinking Water	Result mg/lit	Result mg/lit	Conclusion
1	Turbidity	1 N. T. U. Max	0.43 NTU		
2	pH	6.5 to 8.5	7.00		
3	Total Hardness (as CaCO ₃)	200 mg/lit	28 mg/lit		
4	Chloride	250 mg/lit	4 mg/lit		
5	Calcium	75 mg/lit	4.80 mg/lit		

NOTE - SAMPLE NOT DRAWN BY THIS LABORATORY


CHIEF CHEMIST
WATER TREATMENT PLANT, NIGDI, PCMC



PIMPRI CHINCHWAD MUNICIPAL CORPORATION
(W/S) DIVISION

REPORT OF CHEMICAL EXAMINATION OF WATER

NAME - Novel International School

No-WS/LAB/1752/2025.

ADDRESS - Sambhajinagar, Chinchwad.

Date - 21 / 09 /2025.

SOURCE - PCMC Water.

Date of Receipt - 19 / 09 /2025.

Date of Examination - 21 / 09 /2025

Sr.No.	Tests	I. S Standards for Drinking Water	Result mg/lit	Result mg/lit	Conclusion
1	Turbidity	1 N. T. U. Max	1.05 NTU.		
2	pH	6.5 to 8.5	7.34		
3	Total Hardness (as CaCO ₃)	200 mg/lit	112 mg/lit		
4	Chloride	250 mg/lit	24 mg/lit		
5	Calcium	75 mg/lit	25.65 mg/lit		

NOTE - SAMPLE NOT DRAWN BY THIS LABORATORY


CHIEF CHEMIST
WATER TREATMENT PLANT, NIGDI, PCMC